

FLAMMABLE STORAGE INSPECTION CHECKLIST

CAMPUS _____ DATE _____

BUILDING _____ ROOM _____

Instructions. Check (☒) each item below as "Satisfactory" or "Unsatisfactory." Add any pertinent comments and the location of hazards in the space provided for each item checked "Unsatisfactory."

Condition	N/A	Sat	Unsat	Comment/Location
Flammables are stored away from heat or other sources of ignition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
If flammable liquids in the work area exceed 10 gallons, they are stored in an approved flammable liquid storage cabinet	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Flammable liquids are stored in their original containers or in approved safety cans	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Flammable liquid containers are properly labeled	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Mechanical ventilation is provided in all work areas where flammable liquids are dispensed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Flammable liquid storerooms have at least gravity ventilation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
NO SMOKING signs are clearly posted	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Appropriate spill clean-up materials are available	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Flammable liquid storage rooms are clearly marked	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Fire extinguishers are appropriate for Class B flammable liquid fires	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Fire extinguishers are located within 50 ft. of each area where Class B fires are likely	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
55-gallon drums dispensing flammable liquids are properly bonded and grounded	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Other _____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
CORRECTIVE ACTION TAKEN (indicate if work order has been initiated)				

Inspector's Signature

Print Name